



## **REQUEST FOR PROPOSALS**

**RFP No. 26-0259 ADDENDUM 1**

**Waste Water Treatment System Upgrade  
for**

**Hawaii Health Systems Corporation  
West Hawaii Region  
Kona Community Hospital**

Yvonne Taylor, Sr. Contracts Manager  
West Hawaii Region  
79-1019 Haukapila Street  
Kealakekua, HI 96750  
Telephone (808) 322-4442  
Fax (808) 322-4488  
<http://www.kch.hhsc.org/>

An Agency of the State of Hawaii

1. Addendum 1 provides the following questions submitted by Offerors and corresponding answers provided by KCH:

- a. I have reviewed the RFP for the replacement wastewater treatment system (RFP HHSC 26-0259) and am emailing to see if you are accepting substitution requests for the package wastewater treatment system.  
*No substitutions will be accepted.*
- b. Regarding Item Nine (9) on the Proposal Schedule, which states "12" DI sewer line, including trench, pipe, and fittings, in place complete," GBI is requesting clarification on the following:
  1. The proposed location of the sewer line, and
  2. A profile of the proposed sewer line, including relevant elevations and alignment.

*Proposal schedule will be revised to show 6" DI Sewer line, instead of 12" DI Sewer line.*

- c. Please provide a plan and profile for the proposed 6" sewer line and manhole, including the alignment, elevations, and relevant construction details. Additionally, provide tie-in information for the 6" outflow line, including the connection point, invert elevations, and any applicable specifications or standards.

*The 6-inch sewer line will be located on the effluent side and buried 18-inches below the finished surface, extending toward the new sewer manhole and continuing toward the tie-in (see attached Exhibit D) The Contractor shall field-verify the invert elevation and location of the existing 6-inch sewer line.*

2. Addendum 1 provides the revised Proposal Schedule which reflects the change to 6" sewer line. The Word document is posted on the KCH Procurement page.
3. Addendum 1 also adds a bid security requirement. In accordance with section 2.8 of the 1999 Interim General Conditions, a bid security of 5% is required to be submitted with your proposal. Electronic copy should be submitted with your proposal with original delivered to KCH attn.: Contracts Dept within 3 days of proposal due date.
4. The Word document of the updated Proposal Checklist is posted on the KCH Procurement page.
5. The Mandatory Tabs section has also been updated as follows:

Mandatory Tabs
1. PROPOSAL TRANSMITTAL COVER LETTER
2. TECHNICAL SECTION
SUMMARY
APPENDIX E, MANDATORY QUESTIONS
3. PRICE
APPENDIX M, PRICE SCHEDULE
REQUIREMENTS (see section 3.9)
4. REQUIRED DOCUMENTATION/COMPLIANCE DOCUMENTS
W-9
VENDOR TERMS AND CONDITIONS (if any)
CONFIDENTIALITY AGREEMENT (Appendix H)
STATE OF HAWAII VENDOR CERTIFICATE OF COMPLIANCE (copy)
GENERAL EXCISE LICENSE (copy)
GENERAL CONTRACTOR LICENSE (copy)
LETTER FROM SURETY COMMITTING TO PROVIDE PAYMENT AND PERFORMANCE BOND
BID SECURITY
5. PROPOSAL SUBMISSION CHECKLIST