



REQUEST FOR PROPOSALS

RFP No. 26-0259 ADDENDUM 2

**Waste Water Treatment System Upgrade
for**

**Hawaii Health Systems Corporation
West Hawaii Region
Kona Community Hospital**

Yvonne Taylor, Sr. Contracts Manager
West Hawaii Region
79-1019 Haukapila Street
Kealakekua, HI 96750
Telephone (808) 322-4442
Fax (808) 322-4488
<http://www.kch.hhsc.org/>

An Agency of the State of Hawaii

1. Addendum 2 provides the following question* submitted by an Offeror and its corresponding answer provided by KCH:

Could you please clarify the scope of work and limits for the asphalt paving work on this project? The shaded "New AC Pavement" areas are indicated on the "Existing and Demolition Plan" and the "Site and Grading Plan", per Legend, but there is no corresponding Demolition Notes or Construction Notes. The only detail provided on Sheet C-401 is for trench patching. The Spec Section 02513 for Asphalt Concrete Paving also has contradicting statements for both the removal of existing pavement, and the overlay of new pavement on top of existing pavement.

This response clarified the scope of asphalt concrete (AC) and concrete pavement work for the project.

1. Clarification of Plan Notation:

The shaded areas labeled "New AC Pavement" and any similar notations for concrete pavement on the Existing and Demolition Plan and the Site and Grading Plan are incorrect. These areas shall be interpreted as Existing Pavement to remain. No new parking pavement construction (either full-depth reconstruction or overlay) is included in the project scope.

2. Scope of Paving Work:

The only pavement work required under this contract consists of repairs to existing pavement. This includes trench patching and other localized repairs necessitated by the new utility work or as specifically noted on the plans. All repairs shall conform to the Trench Patching Detail on Sheet C-401 and the repair standards specified in the contract documents. No removal of existing pavements areas, and no overlaying of existing pavement areas, is required.

3. Resolution of Specification Conflict:

Specification Section 02513 (Asphalt Concrete Paving) shall be applied only for repair work as described above. Any language with Section 02513 pertaining to the removal of existing pavement are the overlay of new pavement on top of existing pavement is not applicable to this project and shall be disregarded. The scope defined in this RFI response takes precedence.

SUMMARY:

In summary, the project involves no new AC or concrete pavement construction. The work is limited to repairs of existing pavement in accordance with provided detailed and specifications.

**This question was received late, however KCH is providing this addendum for the benefit of all Offerors. The proposal due date remains the same.*